



SAV Series 41 Check Valves

AWWA C508 Certificate of Compliance

This letter is to certify that all 3-inch through 12-inch Series 41 resilient seated and bronze seated check valves manufactured by Steel Arch Valves Company in Kansas City, Kansas, meet or exceed the standards established by AWWA for Swing Check Valves; ANSI/AWWA C508.

The valves are rated by Steel Arch Valves Co. for a working pressure of 250 psi. Each valve is shell tested to 500 psi and seal tested for complete operation at 250 psi.

If you have any questions or need further information, please feel free to contact us.

On behalf of Steel Arch Valves,

A handwritten signature in blue ink, reading "John Wilber".

John Wilber

VP Engineering
Steel Arch Valves Company

Steel Arch Valves Company

An ISO 9001 and ISO 14001 registered company
© Copyright SAV Group.

Expect... SAV