



SAV Series 45 and Series 55 Gate Valves

AWWA C515 Certificate of Compliance

This letter is to certify that all Series 45 and Series 55 resilient wedge ductile iron gate valves manufactured by Steel Arch Valves Company in Kansas City, Kansas, meet or exceed the standards established by AWWA for Resilient Seated Gate Valves; ANSI/AWWA C515.

The valves are rated by Steel Arch Valves Co. for a working pressure of 250 psi. Each valve is shell tested to 500 psi and tested for complete operation at 250 psi and 25 psi before shipment.

In addition, all Steel Arch Valves gate valves have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of Steel Arch Valves,

A handwritten signature in black ink, appearing to read 'John Wilber'.

John Wilber

VP Engineering
Steel Arch Valves Company